

## Declaration of Performance

DoP - NCA S700 issue A

- 1 Product:** NCA Series 700
- 2 Intended use:** Fire damper
- Intended to be used in conjunction with partitions to maintain fire compartments in heating, ventilating and air conditioning installations
- 3 Manufacturer:** HVC Supplies (Stourbridge) Ltd  
Jason House  
91 - 95 King William Street  
Amblecote  
West Midlands  
DY8 4EY  
United Kingdom
- www.h-v-c.com
- 5 System of AVCP:** System 1
- 6 Harmonised standard:** EN 15650:2010
- Notified body:** 0370  
LGAI Technological Center, S.A (Aplus)
- Certificate of constancy of performance no.:** 0370-CPR-3904
- 7 Declared performances:** See below

### Essential characteristics: Fire resistance

Installation code	Frame type	Supporting construction		Orientation	Nominal size range (w x h, mm)		Classification (EN 13501-3)
		Type	Details		Minimum	Maximum	
S700-2VP	Plate	Flexible wall	Thickness $\geq 130\text{mm}$ Fire resistance $\geq 120$ minutes	Vertical	200 x 200	2074 x 2074	E 120 (ve i↔o) S
S700-2VM	Plate	Rigid wall	Thickness $\geq 130\text{mm}$ Fire resistance $\geq 120$ minutes	Vertical	200 x 200	2074 x 2074	E 120 (ve i↔o) S
S700-2HC	Plate	Concrete floor	Thickness $\geq 150\text{mm}$ Density $\geq 600\text{kg/m}^3$	Horizontal	200 x 200	1000 x 1000	E 120 (ho i↔o) S

### Essential characteristics: Other

Nominal activation conditions/sensitivity: • sensing element load bearing capacity • sensing element response temperature	Pass
Response delay (response time): • closure time	16s (Pass)
Operational reliability: • cycling (50 cycles)	Pass
Durability of response delay: • sensing element response to temperature and load bearing capacity	Pass
Durability of operational reliability • open and closing cycle tests (10,000 cycles)	Pass

### Non-essential characteristics

Damper blade leakage (EN 1751:2014)	Class 2
Damper case leakage (EN 1751:2014)	Class C

The performance of the product identified above is in conformity with the set of declared performance/s.

This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:



**Mr Kerry Allen**  
Operations Director

Amblecote, 27/05/2020